

TYPE APPROVAL CERTIFICATE

This is to certify:

That the High Voltage Cable

with type designation(s)

AFITOX MEP BC/MEP S 3,6/6 kV, AFITOX MEP BC/MEP S 6/10 kV, AFITOX MEP BC/MEP S 8,7/15 kV, AFITOX MEP BC/MEP S 12/20kV

Issued to

NEXANS BRASIL S/A.
Rio de Janeiro, Brazil

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

High voltage cable

Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.

Type	Rated voltage (kV)	Temp. class (°C)
AFITOX MEP BC/MEP S 3,6/6 kV	3,6/6	90
AFITOX MEP BC/MEP S 6/10 kV	6/10	90
AFITOX MEP BC/MEP S 8,7/15 kV	8,7/15	90
AFITOX MEP BC/MEP S 12/20kV	12/20	90

Issued at **Høvik** on **2018-09-21**

This Certificate is valid until **2021-12-31**.

for **DNV GL**

DNV GL local station: **Station Rio de Janeiro, Ship**

Approval Engineer: **Georgy Abramenko**

.....
Marta Alonso Pontes
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-026380-1**
 Certificate No: **TAE00002S7**

Product description

Construction:
 Conductors: Tinned or plain, stranded copper class 2 or class 5 (-F)
 Conductor screen: Semiconducting compound
 Core insulation: HF HEPR
 Insulation screen: Semiconducting compound + tinned or plain copper tape
 Inner covering: Halogen free compound
 Metal covering: Galv. Steel wire braid (S) or tinned or plain copper wire braid (BC)
 Outer sheath: SHF1

AFITOX MEP BC/MEP S 3,6/6 kV; 6/10kV and 8,7/15kV

Number of cores	Conductor cross-section [mm ²]
1	25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500
3	25, 35, 50, 70, 95, 120, 150, 185, 240

AFITOX MEP BC/MEP S 12/20 kV

Number of cores	Conductor cross-section [mm ²]
1	35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500
3	35, 50, 70, 95, 120, 150, 185, 240

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-354	2014-08	Electrical installations in ships - Part 354: Single- and three-core power cables with extruded solid insulation for rated voltages 6 kV (Um = 7,2 kV) up to 30 kV (Um = 36 kV)	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen

Job Id: **262.1-026380-1**
Certificate No: **TAE00002S7**

Standard	Release	General description	Limitation
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Marking of product

NEXANS - AFITOX MEP BC or AFITOX MEP S - Size - 3,6/6 kV or 6/10 kV or 8,7/15 kV or 12/20 kV – IEC 60332-3-22

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE